

ARL-CR-0773 • May 2015



US Army Research Laboratory

Demonstration of Supervisory Control and Data Acquisition (SCADA) Virtualization Capability in the US Army Research Laboratory (ARL)/Sustaining Base Network Assurance Branch (SBNAB) US Army Cyber Analytics Laboratory (ACAL) SCADA Hardware Testbed

prepared by Daniel T Sullivan

Raytheon Company 22260 Pacific Blvd Dulles, VA

and

Edward J Colbert, PhD

ICF International 7125 Thomas Edison Drive #100 Columbia, MD

under contract W911QX-14-F-0020

Approved for public release; distribution unlimited.

NOTICES

Disclaimers

The findings in this report are not to be construed as an official Department of the Army position unless so designated by other authorized documents.

Citation of manufacturer's or trade names does not constitute an official endorsement or approval of the use thereof.

Destroy this report when it is no longer needed. Do not return it to the originator.



Demonstration of Supervisory Control and Data Acquisition (SCADA) Virtualization Capability in the US Army Research Laboratory (ARL)/Sustaining Base Network Assurance Branch (SBNAB) US Army Cyber Analytics Laboratory (ACAL) SCADA Hardware Testbed

prepared by Daniel T Sullivan
Raytheon Company
22260 Pacific Blvd
Dulles, VA

and

Edward J Colbert, PhD
ICF International
7125 Thomas Edison Drive #100
Columbia, MD

under contract W911QX-14-F-0020

REPORT DOCUMENTATION PAGE Form Approved OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.

1. REPORT DATE (DD-MM-YYYY)	2. REPORT TYPE	3. DATES COVERED (From - To)
May 2015	Final	07/2014–12/2014
4. TITLE AND SUBTITLE		5a. CONTRACT NUMBER
Demonstration of Supervisory	Control and Data Acquisition (SCADA)	W911QX-14-F-0020
	ne US Army Research Laboratory	5b. GRANT NUMBER
	ork Assurance Branch (SBNAB)	
US Army Cyber Analytics La	boratory (ACAL) SCADA Hardware Testbed	5c. PROGRAM ELEMENT NUMBER
6. AUTHOR(S)		5d. PROJECT NUMBER
Daniel T Sullivan and Edward	l J Colbert, Ph.D	
		5e. TASK NUMBER
		5f. WORK UNIT NUMBER
7. PERFORMING ORGANIZATION NA	ME(S) AND ADDRESS(ES)	8. PERFORMING ORGANIZATION REPORT NUMBER
Raytheon Company	ICF International	
	7125 Thomas Edison Drive #100	ARL-CR-0773
Dulles, VA 20166	Columbia, MD 21046	
9. SPONSORING/MONITORING AGE	NCY NAME(S) AND ADDRESS(ES)	10. SPONSOR/MONITOR'S ACRONYM(S)
US Army Research Laborator	y	
ATTN: RDRL-CIN-S		11. SPONSOR/MONITOR'S REPORT NUMBER(S)
2800 Powder Mill Road		
Adelphi, MD 20783-1138		

12. DISTRIBUTION/AVAILABILITY STATEMENT

Approved for public release; distribution unlimited.

13. SUPPLEMENTARY NOTES

ARL POC: Robert J Reschly

14. ABSTRACT

In support of the US Army Research Laboratory (ARL) mission to conduct cybersecurity research to protect Industrial Control Systems (ICS), the ARL Sustaining Base Network Assurance Branch (SBNAB) constructed a Supervisory Control and Data Acquisition (SCADA) hardware testbed to simulate the network traffic between human machine interface (HMI) and programmable logic controller (PLC) components. The HMI and PLC components were instantiated with software and installed in multiple virtual machines (VMs) to emulate 6 conceptual manufacturing plant processes. Two experiments were conducted:

- Validate the virtualized network performance by creating and capturing HMI–PLC network traffic over a 24-h period in the virtualized network and inspect the packets for errors.
- Test the interoperability of physical network elements with the virtualized network. In this test, a simulated threat
 actor used a laptop computer to connect to the virtualized production network and send malicious Modbus network
 commands to create a manipulation of view attack.

The results of both experiments are PASS. The experiments validated the capability to establish a SCADA hardware testbed using virtualization and this infrastructure is now part of the ARL SBNAB US Army Cyber Analytics Laboratory (ACAL).

15. SUBJECT TERMS

SCADA, Modbus, virtualization

16. SECURITY CLASSIFICATION OF:		17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON Daniel T Sullivan	
a. REPORT b. ABSTRACT c. THIS PAGE		ABSTRACT	FAGES	19b. TELEPHONE NUMBER (Include area code)	
Unclassified	Unclassified	Unclassified	UU	32	301-394-0248

Contents

List of Figures						
Lis	st of Tables	iv				
Ac	knowledgments	V				
1.	Background and Motivation	1				
2.	Description of Test	1				
	2.1 Test Processes	1				
	2.2 Virtual Representation of the MRE SCADA system	2				
	2.3 PLC Configuration	4				
	2.4 HMI Configuration	5				
3.	Execution of MRE Test	g				
	3.1 Network Virtualization Subtest	g				
	3.2 Simulated Cyber Attack	10				
4.	MRE Test Results	11				
	4.1 Network Virtualization Subtest	11				
	4.2 Simulated Cyber Attack	11				
5.	Conclusions	13				
6.	References	14				
Аp	ppendix A. Experiment Hardware and Software	15				
Аp	ppendix B. ModbusPal Tables	17				
Lis	st of Symbols, Abbreviations, and Acronyms	23				
Dis	stribution List	24				

List of Figures

Fig. 1	Process map for MRE SCADA system2
Fig. 2	Testbed architecture
Fig. 3	Field network VMs4
Fig. 4	Overall plant HMI dashboard6
Fig. 5	Chicken cooker dashboard7
Fig. 6	Vegetable cooker dashboard7
Fig. 7	Meal preparation dashboard8
Fig. 8	High-pressure processing dashboard8
Fig. 9	Main conveyor belt dashboard9
Fig. 10	Product packaging dashboard9
Fig. 11	Meal preparation dashboard before cyber attack
Fig. 12	Meal preparation dashboard after cyber attack12
Fig. 13	Meal preparation alarm panel after cyber attack13
List of	Tables
m 11	NY 1 . 2 . 2
Table	Network virtualization test results
Table A	
Table A	-2 Software list16
Table B	-1 Configuration and measurements for chicken cooker PLC18
Table B	-2 Configuration and measurements for vegetable cooker PLC19
Table B	-3 Configuration and measurements for meal preparation and packaging PLC
Table B	-4 Configuration and measurements for high-pressure processing PLC 21
Table B	-5 Configuration and measurements for main conveyor belt PLC22
Table B	-6 Configuration and measurements for packaging PLC22

Acknowledgments

We greatly appreciate Dr Alexander Kott, Curtis Arnold, and Chuck Smith for supporting Industrial Control Systems/Supervisory Control and Data Acquisition (ICS/SCADA) research at the US Army Research Laboratory (ARL). We are grateful to Kin Wong and Carlos Mateo for help with the SCADA lab design and ordering lab equipment. Max Turk, Akhil Oniha, and James Herron were very helpful in setting up hardware and software in the testbed.

INTENTIONALLY LEFT BLANK.

1. Background and Motivation

This report describes a test experiment executed on the US Army Research Laboratory (ARL) Sustaining Base Network Assurance Branch (SBNAB) Supervisory Control and Data Acquisition (SCADA) hardware testbed. This initial test experiment has been executed to demonstrate SCADA virtualization capability on the testbed. The SCADA hardware testbed is part of the US Army Cyber Analytics Laboratory (ACAL), which provides hardware and network infrastructure and other support needed for collaboration between ARL and other government and commercial institutions.

In this test, we use a software-emulated programmable logic controller (PLC) and public domain human machine interface (HMI) controller software instead of actual PLC hardware and vendor-based HMI software. Both PLC and HMI controller software run inside virtual machines (VMs), allowing the entire SCADA system to be virtualized. In the future, real PLC hardware and commercial HMI software will also be used in ACAL SCADA testbed research experiments.

This initial test of the ACAL SCADA testbed emulates network traffic found in SCADA systems (or Industrial Control Systems [ICS]), as we demonstrate below.

2. Description of Test

2.1 Test Processes

The SCADA system emulated in this test is that of a conceptual Meals-Ready-to-Eat (MRE) manufacturing process. The process map for the system is illustrated in Fig. 1 and shows 6 PLCs controlling various pieces of machinery used to produce the MREs.




Fig. 1 Process map for MRE SCADA system

2.2 Virtual Representation of the MRE SCADA system

The software used in the test emulates the traffic sent and received by PLCs and HMIs found in MRE SCADA processes. The PLCs control machinery and receive sensor inputs from physical plant components. HMIs are computers running control software that frequently polls a PLC for status information about the controlled process. A human plant operator monitors the HMI computer and software. HMIs may also provide a capability for the human operator to manually control a process, if needed.

In this experiment, the HMI and PLC components function within VMs. The testbed topology of VMs used for the MRE SCADA test is depicted in Fig. 2. Six pairs of PLCs and HMIs have been constructed inside a virtual network, and all 12 VMs are connected to virtual switches. An attacker, who also has access to the virtual network via a virtual switch, can initiate attacks on the MRE SCADA system.




Fig. 2 Testbed architecture

A more detailed diagram of the simulated SCADA network is shown in Fig. 3 and additional information is presented in Appendix A. Experiment Hardware and Software. In this experiment, each HMI polls a simulated PLC using the industrial Modbus transmission control protocol (TCP). The HMI software used in this test is the open source Mango Automation application, while the simulated PLC software is the open source ModbusPal Java application. When queried using the Modbus TCP protocol, ModbusPal reports coil and holding register values in a manner similar to a real PLC. For each HMI–PLC pair, Modbus network traffic will be captured by the tcpdump utility. This captured traffic is used to check if packet loss or network errors occur in the virtualized hosts or network during the experiment.




Fig. 3 Field network VMs

The HMI and PLC VMs are hosted by a VMware ESXi hypervisor on a Dell R610 server. For each HMI–PLC pair, a virtual switch connects the 2 VMs. Each virtual switch is part of the same virtual network. The virtual network is also mapped to one of the host machine's network interface cards (NICs) and this NIC allows external access to the virtual network, for example, to the attacker.

2.3 PLC Configuration

Each ModbusPal virtual PLC instance must be configured with a set number of holding registers and coils to simulate the corresponding process presented in Figs. 1 and 2. ModbusPal was configured with an Extensible Markup Language (XML)-based text file where holding registers and coils are defined and values specified. The values of holding registers and coils can be controlled programmatically within ModbusPal.

In Appendix B. ModbusPal Tables, we list the detailed configuration information for each of the 6 PLCs controlling the 6 processes (see Fig. 2):

1. Chicken cooker

- 2. Vegetable cooker
- 3. Meal preparation and packaging
- 4. High-pressure processing
- 5. Main conveyor belt
- 6. Packaging

2.4 HMI Configuration

Each virtualized Mango HMI polls its respective ModbusPal PLC for its values of coils and holding registers every 10 seconds (sec). The Mango software will send Modbus TCP requests to ModbusPal to request values of all holding registers and coils configured for this experiment. A graphical dashboard will also be configured to provide situational awareness, see Fig. 4 for the overall dashboard, which represents the view typically seen in industrial plants.




Fig. 4 Overall plant HMI dashboard

Snapshots are shown of the 6 Mango HMIs in Figs. 5–10, illustrating the HMI dashboards of each of the 6 processes.




Fig. 5 Chicken cooker dashboard




Fig. 6 Vegetable cooker dashboard




Fig. 7 Meal preparation dashboard




Fig. 8 High-pressure processing dashboard




Fig. 9 Main conveyor belt dashboard




Fig. 10 Product packaging dashboard

3. Execution of MRE Test

The MRE test consists of 2 parts—a network virtualization test and a simulated cyber-attack. A description of these 2 subtests follows.

3.1 Network Virtualization Subtest

In this subtest, we will validate that each HMI-PLC pair of VMs has network connectivity and that the network paths are configured correctly.

Step 1: For each automation process, once the Mango HMI begins polling its respective ModbusPal instance, capture the traffic over a 24-hour (h) period using tcpdump.

Step 2: During the 24-h polling process, perform spot checks to verify the Mango HMI is receiving measurements in compliance with the values listed in Tables 2–7.

Step 3: Use Wireshark to inspect the 24-h tcpdump captures and check for any Internet Control Message Protocol (ICMP) error messages in the tcpdump files. The condition for PASS requires that no ICMP error messages exist in the tcpdump files. The condition for FAIL requires that one or more ICMP error messages are found. If ICMP error messages in the tcpdump files are discovered, investigate the reasons and correct the configuration.

3.2 Simulated Cyber Attack

This subtest simulates a cyber-attacker sending malicious Modbus messages to a PLC to change the values of coils. The Modbus protocol does not have security capabilities to authenticate messages or prevent replay attacks.² As a result, anyone (insider or external threat actor) who has knowledge of the process map can send malicious Modbus messages to a PLC and impact an automation process. External threat actors can gain knowledge of the process map and PLC ladder logic by conducting reconnaissance of the plant network prior to an attack.

In this subtest, we will conduct a manipulation of view attack on the Meal Preparation ModbusPal instance. In a real plant environment, this attack would cause the production process to stop while plant operators investigate the cause.

Step 1: On an external laptop connected to the experiment network, use the Perl "mbtget" script to change the Meal Preparation PLC Robot Arm and Sealing System coil values to "0" ("Off" state).

Step 2: Monitor the Meal Preparation process Mango HMI dashboard. The dashboard should show the Robot Arm and Sealing System processes are in an "Off" state and an alarm should be visible. The test is a PASS if the Meal Preparation dashboard shows both processes are "Off" and alarm symbols are displayed.

4. MRE Test Results

4.1 Network Virtualization Subtest

The topdump data captured over a 24-h period of each HMI-simulated PLC pair were examined using Wireshark. The table presents the number of packets captured and examined for each HMI and simulated PLC pair. The number of network errors are also listed. Because no network errors were found, all tests were a PASS.

Automation Process	Number of Mango HMI– ModbusPal Packets Captured over 24 h	Number of Network Errors	Test Results (PASS/FAIL)
Chicken cooker	172,904	0	PASS
Vegetable cooker	172,806	0	PASS
Meal preparation	172,818	0	PASS
High-pressure processing	172,807	0	PASS
Main conveyor belt	172,803	0	PASS
Product packaging	86,402	0	PASS

Table Network virtualization test results

For each automation process, the Mango HMI polled its respective ModbusPal application every 10 sec. In each polling period, Mango HMI issued a Modbus coil read request and waited for the response. After receiving the coil measurements, the Mango HMI sent a holding register read request to its respective ModbusPal application. Therefore in each 10-sec poll interval, 2 Modbus read requests are sent and 2 responses are received by the HMI.

The number of Modbus packets for the Product Packaging process was much less than the other automation processes because Product Packaging only used holding registers. Therefore, in each 10-sec polling interval, Mango sent only one Modbus message compared to 2 in the other automation processes.

4.2 Simulated Cyber Attack

We show the Meal Preparation HMI dashboard during normal operations and after the attacker has sent malicious traffic, in Figs. 11 and 12, respectively.




Fig. 11 Meal preparation dashboard before cyber attack




Fig. 12 Meal preparation dashboard after cyber attack

The attack was simulated using the Perl mbtget script, which sent Modbus coil write messages to the Meal Preparation ModbusPal to set the coil values to "0" (turn the process offline). The small yellow triangles with an "!" symbol in the

upper part of Fig. 12 are alarms that have consequently sounded in the Mango dashboard for this critical process.

Fig. 13 is a screen capture of the Meal Preparation HMI alarm panel. The loss of the Robot Arm and Sealing System processes are listed as critical alarms.



Fig. 13 Meal preparation alarm panel after cyber attack

This attack would have resulted in a shutdown of the Meal Preparation process if this were an actual plant. The test result is PASS.

5. Conclusions

This experiment demonstrates that virtualization of SCADA components is an effective means to simulate a production plant's network traffic and create cyberattack scenarios. The VMs and guest operating systems with their applications emulated the automation components found in a plant and zero packets were lost by the virtual network. The virtual environment enabled us to simulate a cyberattack on a commonly used Modbus industrial protocol. We will leverage the results of this experiment in future tests to protect critical infrastructure.

6. References

- 1. Mango Automation. Version 2.4.2, Intelligent Automation Systems, Inc. http://infiniteautomation.com/index.php/software/. [accessed Oct 8 2014].
- 2. Modbus. Digital Bond Incorporated. n.d. http://www.digitalbond.com/scadapedia/protocols/modbus-2/. [accessed Jan 14 2015].

Appendix A. Experiment Hardware and Software

Table A-1 presents each hardware component with a description of its use and operating system.

Table A-1 Hardware list

Platform	Function	Operating System
Mac laptop and desktop	Remote access to Virtual	OS X Mavericks
	Machines (VMs), configure (Version 10.9)	
	applications for experiment	
Dell R610	Hosts ESXi	ESXi 5.5 hypervisor
Dell R710	Software development and testing	CentOS 6.5
	of applications	
Dell PowerConnect 6224	Network switch	Dell Firmware

The software for this experiment is presented in Table A-2 for each hardware platform. This experiment will use US Army Research Laboratory (ARL) licensed, as well as open source software and operating systems.

Table A-2 Software list

Software	Function	Platform
VirtualBox	Hosts Windows Vista on Mac	Mac laptop and desktop
	platforms	computers
Windows Vista	Guest OS of VirtualBox. Enables Mac	Mac laptop and desktop
Enterprise	users to access ESXi VMs using vSphere client.	computers
ESXi 5.5	Hypervisor to host guest VMs	Dell R610
vSphere Client 5.5	Remote access to ESXi VMs	Mac laptop and desktop computers
CentOS 6.5	Operating system	Dell R710 and each VM
		hosting the simulated
		PLC and Mango HMI
Java Software	Compile ModbusPal PLC simulator	Dell R710
Development Kit (JDK) 1.7		
Java Runtime	Run Mango HMI and ModbusPal PLC	Dell R710 and each VM
Environment (JRE) 1.7	simulator	
Eclipse	Development tool to program the ModbusPal PLC simulator	Dell R710
Perl 5.10.1	Runs mbtget script to simulate a cyber attacker	Cyber attacker VM, Dell R710
Mango	HMI which polls simulated PLC	VMs simulating an HMI
	(ModbusPal) for status messages	workstation
ModbusPal	Simulates a PLC	VMs simulating a PLC
mbtget	Simulates a cyber attacker. Sends	Cyber attacker VM
	scripted Modbus messages to simulated PLCs.	
tcpdump	Captures Modbus packets	Each VM

Appendix B. ModbusPal Tables

Tables B-1 through B-6 list the coil and holding register configuration of each ModbusPal application to emulate its respective Programmable Logic Controller (PLC) depicted in the Fig. 1 process map.

Table B-1 Configuration and measurements for chicken cooker PLC

Entity	Holding Register Index	Coil Index	Allowed Value	Value Set for Experiment	Data Type
Oven Door Open/Closed		1	1 = Oven door is OPEN 0 = Oven door is Closed	0	Bit
Gas Flow On/Off		2	1 = Gas turned ON to oven 0 = Gas turned OFF to Oven	1	Bit
Exhaust Fan On/Off		3	1 = Exhaust Fan is ON 0 = Exhaust Fan is OFF	1	Bit
Conveyor In Motion		4	1 = belt is moving forward0 = belt is stopped	0	Bit
Oven Temperature (°F)	1		345–355 when Oven is ON	ModbusPal automation to randomly choose values between 345–355	2 Byte Signed Integer
Oven Temperature Maximum (°F)	2	•••	360	360	2 Byte Signed Integer
Oven Temperature Minimum (°F)	3		340	340	2 Byte Signed Integer
Cooking Time Remaining (min)	4		0–30	ModbusPal automation to linearly decrement time from 30 to 0	2 Byte Signed Integer

Table B-2 Configuration and measurements for vegetable cooker PLC

Entity	Holding Register Index	Coil Index	Allowed Values	Value Set for Experiment	Data Type
Oven Door Open/Closed		1	1 = Oven door is OPEN 0 = Oven door is Closed	0	Bit
Gas Flow On/Off		2	1 = Gas turned ON to oven 0 = Gas turned OFF to Oven	1	Bit
Exhaust Fan On/Off		3	1 = Exhaust Fan is ON 0 = Exhaust Fan is OFF	1	Bit
Conveyor In Motion		4	1 = Belt is moving forward0 = Belt is stopped	0	Bit
Oven Temperature (°F)	1		370–380 when Oven is ON	ModbusPal automation to randomly choose values between 370– 380	2 Byte Signed Integer
Oven Maximum Temperature Alarm Set Point (°F)	2		390	390	2 Byte Signed Integer
Oven Minimum Temperature Alarm Set Point (°F)	3		360	360	2 Byte Signed Integer
Cooking Time Remaining (min)	4		0–20	ModbusPal automation to linearly decrement time from 20 to 0	2 Byte Signed Integer
Cooking Time Duration (min)	5		20	20	2 Byte Signed Integer

Table B-3 Configuration and measurements for meal preparation and packaging PLC

Entity	Holding Register Index	Coil Index	Allowed Values	Value Set for Experiment	Data Type
Robot Arm Online		1	1 = Robot Arm is in operation 0 = Robot Arm is offline	1	Bit
Sealing System Online		2	1 = Sealing System is on operation0 = Sealing System is offline	1	Bit
Exhaust Fan On/Off		3	1 = Exhaust Fan is ON 0 = Exhaust Fan is OFF	1	Bit
Product Weight (grams)	1		510–740 grams	ModbusPal automation to randomly choose values between 510–740 grams	2 Byte Signed Integer
Product Weight Maximum Alarm Set Point (grams)	2		750	750	2 Byte Signed Integer
Product Weight Minimum Alarm Set Point (grams)	3		500	500	2 Byte Signed Integer

Table B-4 Configuration and measurements for high-pressure processing PLC

Entity	Holding Register Index	Coil Index	Allowed Value	Value Set for Experiment	Data Type
Pressure Door	•••	1	1 = Pressure door is	0	Bit
Open/Closed			OPEN		
			0 = Pressure door is Closed		
Water Fill		2	1 = Water Fill Pump	0	Bit
Pump On/Off			is ON		
			0 = Water Fill Pump		
Pressure Pump		3	is OFF 1 = Pressure Pump is	1	Bit
On/Off	•••	3	ON	1	DΙΙ
			0 = Pressure Pump is		
			OFF		
Product	•••	4	1 = Product is being	1	Bit
Pressuring Process On/Off			pressurized 0 = Product is not		
Flocess Oll/Oll			being pressurized		
Conveyor Belt		5	1 = Belt is moving	0	Bit
In Motion			forward		
			0 = Belt is stopped		2.5
Liquid Level Percent (%)	1	•••	40–60 % when products are being	ModbusPal automation to	2 Byte Signed
Full			pressurized	randomly choose	Integer
1 0.11			pressuring	values between	meger
				40–60	
Pressure (MPa)	2	•••	300–500 when	ModbusPal	2 Byte
			pressurizing process is ON	automation to	Signed
			IS OIN	randomly choose values between	Integer
				300–500	
Maximum	3	•••	275	275	2 Byte
Pressure Alarm					Signed
Set Point (MPa) Minimum	4		525	525	Integer
Pressure Alarm	4	•••	323	525	2 Byte Signed
Set Point (MPa)					Integer
Pressuring Time	5		0–20	ModbusPal	2 Byte
Remaining (s)				automation to	Signed
				linearly decrement time	Integer
				from 20 to 0	
				110111 20 10 0	

Table B-5 Configuration and measurements for main conveyor belt PLC

Entity	Holding Register Index	Coil Index	Allowed Value	Value Set for Experiment	Data Type
Conveyor Belt	•••	1	1 = Belt is moving	1	Bit
In Motion			0 = Belt is stopped		
Motor Oil	1		80–150 °F	ModbusPal	2 Byte
Temperature				automation to	Signed
				randomly choose	Integer
				values between	
				80–150	
Motor Oil	2		45-70% full	ModbusPal	2 Byte
Level (% Full)				automation to	Signed
				randomly choose	Integer
				values between	
				45–70	
Speed (surface	3		55–70 FPM when the	ModbusPal	2 Byte
feet per minute			conveyor belt is	automation to	Signed
[FPM])			moving	randomly choose	Integer
				values between	
				55–70	

Table B-6 Configuration and measurements for packaging PLC

Entity	Holding Register Index	Coil Index	Allowed Value	Value Set for Experiment	Data Type
Packing Tape Available (% Full)	1		0–100%	ModbusPal automation to linearly decrease percentage from 100 to 0	2 Byte Signed Integer
Ink Level (%)	2		0–100%	ModbusPal automation to linearly decrease percentage from 100 to 0	2 Byte Signed Integer
Shipping Container Weight (lbs)	3		150–200 lbs	Used ModbusPal automation to randomly set value between 150 to 200	2 Byte Signed Integer
Shipping Box Inventory (%)	4		0–100%	ModbusPal automation to linearly decrease percentage from 100 to 0.	2 Byte Signed Integer

List of Symbols, Abbreviations, and Acronyms

ACAL US Army Cyber Analytics Laboratory

ARL US Army Research Laboratory

FPM feet per minute

h hour

HMI human machine interface

ICMP Internet Control Message Protocol

ICS Industrial Control Systems

JDK Java Development Kit

JRE Java Runtime Environment

Mac Macintosh

MRE Meals-Ready-to-Eat

NIC network interface card

PLC programmable logic controller

OS operating system

SBNAB Sustaining Base Network Assurance Branch

SCADA Supervisory Control and Data Acquisition

sec second(s)

TCP transmission control protocol

VM Virtual Machine

XML Extensible Markup Language

- 1 DEFENSE TECHNICAL
- (PDF) INFORMATION CTR DTIC OCA
 - 1 DIRECTOR
- (PDF) US ARMY RESEARCH LAB RDRL CIO LL IMAL HRA MAIL & RECORDS MGMT
 - 3 DIRECTOR
- (PDF) US ARMY RESEARCH LAB

RDRL CIN S D SULLIVAN E COLBERT R RESCHLEY